

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0935:106

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Nailor Industries, 4714 Winfield, Houston TX 77039
Contact: John Young (281) 590-1172

DESIGN: Models 1240/D1240 and 1270/D1270 fire rated dampers. These dampers are of the single and multi-blade type construction for vertical and/or horizontal installation. Refer to listee's data sheet for detailed product description and operational considerations.

Model	Single Section				Multiple Section				Position
	Width		Height		Width		Height		
	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	
1240/D1240	8"	32"	8"	48"	16"	91"	8"	48"	V
	NA	NA	NA	NA	8"	32"	16"	91"	V
	32"	8"	16"	36"	16"	91"	8"	36"	H
	NA	NA	NA	NA	8"	32"	16"	91"	H
1270	8"	40"	8"	48"	16"	91"	8"	40"	V
	NA	NA	NA	NA	8"	40"	16"	91"	V
	8"	36"	8"	48"	16"	72"	8"	48"	V
	NA	NA	NA	NA	8"	36"	16"	91"	V
	8"	30"	8"	40"	16"	91"	8"	40"	H
	NA	NA	NA	NA	8"	30"	16"	91"	H
D1270	8"	36"	8"	48"	16"	91"	8"	40"	V
	NA	NA	NA	NA	8"	40"	16"	91"	V
	8"	36"	8"	36"	16"	72"	8"	48"	V
	NA	NA	NA	NA	8"	36"	16"	91"	V
	8"	30"	8"	36"	16"	91"	8"	40"	H
	NA	NA	NA	NA	8"	30"	16"	91"	H

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as fire dampers rated for 1-1/2 hr. All units are intended for use with listee's listed fire damper actuators.

NOTE: Refer to CSFM Listing No. 3230-0935:107 for leakage dampers.

02-17-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 11, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager